



NOTES:

1. ALL CURBS AND SIDEWALKS SHALL BE CONSTRUCTED WITH IDOT CLASS "SI" CONCRETE WITH A MINIMUM COMPRESSIVE STRENGTH OF 3,500 PSI AT 14 DAYS.
2. PARKWAYS SHALL BE FINISHED WITH A MINIMUM OF SIX INCHES OF TOPSOIL.
3. TESTING OF SUBGRADE AND ALL ROADWAY MATERIALS SHALL BE DONE IN ACCORDANCE WITH THE VILLAGE'S SUBDIVISION ORDINANCE.

VILLAGE OF NEW LENOX
STANDARD DETAIL
FOR ROADWAY
CROSS-SECTION
RESIDENTIAL

REV:	8
DATE:	AUG 2014
FILE:	TRANS\RD\XSEC1